



To

Sh. Anil Kumar (Manager)
Swaraj Public School, Swatantar Vihar,
Damla, Distt. Yamunanagar

Memo no. 7709

Dated: 30-01-24

Sub.: Request for issuance of Building Safety Certificate for our School as per CBSE Format.
Ref. Your letter No. SPS/238-23 dated 15.01.2024

In this connection, it is intimated that the building of Swaraj Public School, Swatantar Vihar, Damla, Distt. Yamunanagar has been inspected by the Sub Divisional Engineer, Provincial Sub Division No.1, PWD B&R Br. Yamunanagar alongwith J.E. concerned on 29.01.2024 and has reported that upon visual /physical inspection as well as intimated by the owner of the building that two blocks i.e. Junior Wing and Senior wing were constructed in the year 1999 and 2007 respectively. The Junior wing is double storied building while the senior wing is three storied building and no structural design and drawing (dully proof checked from approved source/ reputed agency like Punjab Engineering College Chandigarh, NIT Kurukshetra and IIT Roorkee etc.) has been supplied by your school and no work has been got executed under the supervision of this office. However, on visual/ physical inspection the building apparently seems to be safe as there is no crack or any other sign of structural failure. The certificate is valid for one year only.

This is for your kind information and further necessary action please.

DA/Nil


Executive Engineer,
Jag. Provl. Divn. PWD (B&R) Br.
Yamuna Nagar


Endst No.

Dated:-

Copy of the above is forwarded to the Sub Divisional Engineer, Provincial Sub Division No.1, PWD B&R Br., Yamunanagar for information. This is with reference to his office letter No. 176 dated 29.01.2024

DA/Nil


Principal
SWARAJ PUBLIC SCHOOL
Damla (Yamuna Nagar)


Manager
SWARAJ PUBLIC SCHOOL
Damla, Yamuna Nagar-135001

sd-
Executive Engineer,
Jag. Provl. Divn. PWD (B&R) Br.
Yamuna Nagar